



DEEP SANITARY SEWER SERVICE: MAIN TO CLEANOUT

MAINLINE > 10' DEEP

N.T.S.

GENERAL NOTES

1. ALL CONNECTIONS SHALL BE GASKETED TYPE. NO GLUED CONNECTIONS OR FLEXIBLE COUPLINGS SHALL BE USED.
2. CONNECTIONS TO EXISTING SEWERS SHALL BE PVC GASKETED TYPE WYE CONNECTION SADDLES.
3. FURANCO COUPLINGS WILL NOT BE ALLOWED.

STANDARDS

1. ASTM D3034

ISSUE DATE: JANUARY 2019

TOWN & VILLAGE OF ELLICOTTVILLE

DATE

COMMENTS

EVL ENG DEPT.

REVISIONS

SEWER - S-02A

