



GENERAL NOTES

1. ALL CONNECTIONS SHALL BE GASKETED TYPE. NO GLUED CONNECTIONS OR FLEXIBLE COUPLINGS SHALL BE USED. TRACER WIRE SHALL BE MADE CONTINUOUS FROM THE CLEANOUT TO THE BASEMENT OR CRAWL SPACE. CUSTOMER TO CONNECT TO TRACER WIRE AT THE POINT OF CONNECTION NEAR THE CLEANOUT.
2. MAINTENANCE OF THE SEWER SERVICE FROM THE RIGHT-OF-WAY TO AND INCLUDING THE INTERNAL PLUMBING ON PREMISES, AND ITS USE, MUST ALWAYS BE KEPT IN FULL COMPLIANCE. THE FOREGOING REMAINS THE SOLE RESPONSIBILITY OF THE SEWER CUSTOMER.
3. THE CUSTOMER MUST SUBMIT A SEWER TAP APPLICATION, OBTAIN TOWN/VILLAGE APPROVAL TO PROCEED, AND SCHEDULE INSPECTIONS PRIOR TO BACKFILLING OR PLACING THE CUSTOMER PORTION IN USE.
4. A LARGER DIAMETER SERVICE LINE MAY BE REQUIRED WHERE DISTANCE OR CUSTOMER DEMAND ARE A FACTOR.

SANITARY SEWER SERVICE:
CLEAN-OUT TO CUSTOMER

N.T.S.

STANDARDS

1. ASTM D3034

ISSUE DATE: SEPTEMBER 2018

TOWN & VILLAGE OF ELLICOTTVILLE

REVISIONS	DATE	COMMENTS

EVL ENG DEPT.

SEWER - S-03

